

Drinking-Water Systems Regulation O. Reg. 170/03

Part III Form 2

Section 11. ANNUAL REPORT. (Amended 22 Feb 06 – amendment made was to remove reference to public notification via Cable TV)

Drinking-Water System Number:	210000951
Drinking-Water System Name:	Verner WTP
Drinking-Water System Owner:	The Corporation of the Municipality of West Nipissing
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	Jan 1, 2005 to Dec 31, 2005

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Municipality of West Nipissing Sturgeon Falls Water Treatment Plant 11 Nipissing Street Sturgeon Falls, Ontario</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	--

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
NA	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
 Yes [] No [] **NA**

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web <http://www.westnipissingouest.ca/pop/dep-utilities.html>

Public access/notice via Government Office

Public access/notice via a newspaper notice given via Sturgeon Falls Tribune newspaper

Public access/notice via Public Request

Public access/notice via a Public Library copies placed at West Nipissing Library

Public access/notice via other method

Describe your Drinking-Water System

The Verner WTP, commissioned in 1975, consists of a full surface water treatment facility, designed capacity of 1059 m³/d, drawing water from the Veuve River that is part of the Nipissing watershed. The intake structure is located 12 km upstream of Lake Nipissing and 48 km downstream of the source. The water treatment plant's intake facility consists of an intake structure located 5 m below the low river level, connected to a raw water wet well by a 42.7 m long, 250 mm ductile iron pipe. The intake structure is approximately 20 m from the riverbank.

The Verner Water Treatment Plant (WTP) is a conventional treatment facility consisting of chemically assisted filtration (through the use of an "Ecodyne Graver Monoplant" package treatment plant), primary disinfection & secondary disinfection. Conventional treatment is comprised of coagulation, flocculation, sedimentation & dual media rapid sand filtration. Furthermore, disinfection is achieved through the use of chlorine dioxide, UV and chlorine gas.

The Ecodyne Graver Monoplant package plant, consisting of a Mixing Zone; Flocculation Zone; Settling Compartment and flock barriers; Blowdown valve and rapid flow by gravity sand and anthracite filters.

Chemical treatment includes the addition of polymer, aluminum sulfate, pre and post soda ash, chlorine for disinfection and chlorine dioxide for iron and manganese removal to control taste and odour.

There are four (4) below grade clear wells connected in series having a total area, total capacity and useable capacity of 134 m², 269 m³ and 234 m³ respectively. The high lift pumping station has a firm capacity of 1,090 m³/d with three (3) identical vertical turbine high lift pumps each having a capacity of 545 m³/d at a TDH of 53.3 m. An elevated storage tank of composite steel/concrete construction, having a total storage capacity of 568 m³ and about 40 m above ground equipped with low level alarm and an overflow is located approximately 23 meters.

Standby power supplied at this plant by a 125 kW standby diesel generator installed in 2005.

List all water treatment chemicals used over this reporting period

Chlorine Gas
Sodium Chlorite
Sodium Carbonate
Aluminum Sulfate (ALUM)
Magnafloc LT20 Poly Acrylamide Polymer

Were any significant expenses incurred to?

- Install required equipment
 Repair required equipment
 Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

The treatment plant under went a major upgrade in 2005 which included replacement of all chemical feed system equipment and tanks, replacement of the plant instrumentation and controls, installation of a UV system for primary disinfection, installation of piping and valves to provide treatment-to-waste functionality, new raw water and treated water magnetic flow meters, and the installation of a 125 kW standby diesel generator. Also radio telemetry equipment was installed at the elevated storage tank to permit treatment plant-elevated tank communication and control. Cost \$ 1,3000,000
 Also
 A new lab pH meter was purchased to replace the old one. Approx. \$1600.00
 The check valves on the low lift discharge header and high lift discharge header were replaced. Approx. \$2500.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
08/Feb/2005	Turbidity	> 2.0	NTU	After filter, turbidity back down to below 1.0 NTU. After backwash, measured treated turbidity at 0.40 NTU.	08/Feb/2005
08/Mar/2005	Turbidity	2.25	NTU	02:50 post filter turbidity @ 2.25 NTU for > 15 min. Backwashed both filters to avoid high turbid water from entering clear wells. 04:50 Post filter turbidity @ < 1.0 NTU	08/Mar/2005
12/Mar/2005	Turbidity	5.4	NTU	15:15 post filter turbidity @ 5.4 NTU for > 15 min. 3 backwashes/filter occurred therefore I estimate that between backwashes, high turbid water entered the clear well. 6 backwashes x 5 min = 30 min. 17:30 post filter turbidity < 1.0 NTU. Closed filter to waste valve. Treated chlorine residual maintained 1.80 mg/L free.	12/Mar/2005
04/Apr/2005	Turbidity	5.20	NTU	Post filter turbidity at 5.2 NTU > 15 minutes. Opened filter to waste valve until turbidity under 1.0 NTU at 14:44. Treated Cl2 residual maintained at 1.96 mg/L.	04/Apr/2005

12/Apr/2005	Turbidity	2.45	NTU	POE water 0.83 NTU. Post filter turbidity > 1.0 NTU for more than 15 min. Lost sludge blanket in graver plant. Opened after filter valve to waste. Measured POE at 0.93 NTU. Cl2 at 1.20 mg/L. Water plant is being upgraded, has new after filter turbidity meter only used for data collection. 2nd older meter used to alarm had airlock, no water through analyzer. Additional information filed in binder.	12/Apr/2005
25/Apr/2005	Turbidity	3.07	NTU	Post filter turbidity 05:08-05:35 max 2.82 NTU at 05:32 NTU Post filter turbidity 05:40-06:17 max 3.07 NTU at 06:15 Opened 2" desludge valve for total of 28 minutes to release extra sludge from plant. CL2 residual at 1.78 mg/L. Measure POE at 0.552 NTU. After filter turbidity 0.23 NTU	25/Apr/2005
29/Jul/2005	Turbidity	> 1.0	NTU	Post filter turbidity > 1.0 NTU for approximately 45 minutes. 06:50 restored post filter turbidity at 0.07 NTU. Free cl2 residual maintained approximately 2.10 mg/L. NOTE UV DISINFECTION ONLINE SINCE 12-JUL-2005. 07:00 POE turbidity at approx 0.90 NTU. Shut off high lifts will continue to dilute clear well.	29/Jul/2005
05/Aug/2005	Turbidity	> 1.0	NTU	Post filter turbidity > 1.0 NTU for approximately 55 minutes. 04:00 restored post filter turbidity < 1.0 NTU. Opened filter to waste 20 minutes. Free cl2 residual maintained approximately 1.75 mg/L. NOTE: UV DISINFECTION ONLINE SINCE 12-JUL-05. 05:00 POE turbidity at approximately 0.53 NTU.	05/Aug/2005

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Results (min #)-(max #)	Range of Total Coli form Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	53	7 - 910	10 - >2000	53	200 - >2000
Treated	53	0 - 0	0 - 0	53	0 - 1
Distribution	164	0 - 0	0 - 0	163	0 - 5

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

Filter Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Post Filter Turbidity	348	0.06 - 0.70 NTU

NOTE: For continuous monitors use 8760 as the number of samples.

POE Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	350	0.08– 9.67 NTU
Free Chlorine	272	0.98 – 4.59 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

Distribution Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Free Chlorine	478	0.27 – 2.18 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

Filter On-line Continuous Analyzers

	Number of Samples	Range of Results (min #)-(max #)
Post Filter Turbidity	8760	0.05– 10.0 NTU

NOTE: For continuous monitors use 8760 as the number of samples.

POE On-line Continuous Analyzers

	Number of Samples	Range of Results (min #)-(max #)
POE Free Chlorine	8760	0 – 2.0 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
C of A 8668-6APPTC issued 14 Jun 2005	UV intensity			
	Flow Rate			
	UV Transmittance			
	UV Lamp Status			

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Jan 18/05	<0.001	mg/L	
Arsenic	Jan 18/05	<0.001	mg/L	
Barium	Jan 18/05	0.0011	mg/L	
Boron	Jan 18/05	<0.006	mg/L	
Cadmium	Jan 18/05	<0.001	mg/L	
Chromium	Jan 18/05	0.003	mg/L	
Lead	Jan 18/05	0.003	mg/L	
Mercury	Jan 18/05	<0.0001	mg/L	

Selenium	Jan 18/05	<0.002	mg/L	
Sodium	Jan 18/05	32	mg/L	yes
Uranium	Jan 18/05	<0.002	mg/L	
Fluoride	Jan 18/05	<0.1	mg/L	
Nitrite	Jan 18/05	<0.1	mg/L	
	May 05/05	<0.1	mg/L	
	Aug 25/05	<0.3	mg/L	
	Nov 29/05	<0.01	mg/L	
Nitrate	Jan 18/05	0.4	mg/L	
	May 05/05	<0.1	mg/L	
	Aug 25/05	1.8	mg/L	
	Nov 29/05	<0.1	mg/L	

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Jan 18/05	<0.5	ug/L	
Aldicarb	Jan 18/05	<5	ug/L	
Aldrin + Dieldrin	Jan 18/05	<0.012	ug/L	
Atrazine + N-dealkylated metabolites	Jan 18/05	<0.5	ug/L	
Azinphos-methyl (Guthion)	Jan 18/05	<2	ug/L	
Bendiocarb	Jan 18/05	<2	ug/L	
Benzene	Jan 18/05	<0.5	ug/L	
Benzo(a)pyrene	Jan 18/05	<0.01	ug/L	
Bromoxynil	Jan 18/05	<0.5	ug/L	
Carbaryl	Jan 18/05	<5	ug/L	
Carbofuran	Jan 18/05	<5	ug/L	
Carbon Tetrachloride	Jan 18/05	<0.5	ug/L	
Chlordane (Total)	Jan 18/05	<0.012	ug/L	
Chlorpyrifos	Jan 18/05	<1	ug/L	
Cyanazine	Jan 18/05	<1	ug/L	
Diazinon	Jan 18/05	<1	ug/L	
Dicamba	Jan 18/05	<1	ug/L	
1,2-Dichlorobenzene	Jan 18/05	<0.5	ug/L	
1,4-Dichlorobenzene	Jan 18/05	<0.5	ug/L	
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Jan 18/05	<0.024	ug/L	
1,2-Dichloroethane	Jan 18/05	<0.5	ug/L	
1,1-Dichloroethylene (vinylidene chloride)	Jan 18/05	<0.5	ug/L	
Dichloromethane	Jan 18/05	<1	ug/L	
2-4 Dichlorophenol	Jan 18/05	<0.5	ug/L	
2,4-Dichlorophenoxy acetic acid (2,4-D)	Jan 18/05	<1	ug/L	
Diclofop-methyl	Jan 18/05	<0.9	ug/L	
Dimethoate	Jan 18/05	<2.5	ug/L	

Drinking-Water Systems Regulation O. Reg. 170/03

Dinoseb	Jan 18/05	<1	ug/L	
Diquat	Jan 18/05	<7	ug/L	
Diuron	Jan 18/05	<10	ug/L	
Glyphosate	Jan 18/05	<10	ug/L	
Heptachlor + Heptachlor Epoxide	Jan 18/05	<0.012	ug/L	
Lindane (Total)	Jan 18/05	<0.006	ug/L	
Malathion	Jan 18/05	<5	ug/L	
Methoxychlor	Jan 18/05	<0.024	ug/L	
Metolachlor	Jan 18/05	<0.5	ug/L	
Metribuzin	Jan 18/05	<5	ug/L	
Monochlorobenzene	Jan 18/05	<0.5	ug/L	
Paraquat	Jan 18/05	<1	ug/L	
Parathion	Jan 18/05	<1	ug/L	
Pentachlorophenol	Jan 18/05	<0.5	ug/L	
Phorate	Jan 18/05	<0.5	ug/L	
Picloram	Jan 18/05	<5	ug/L	
Polychlorinated Biphenyls(PCB)	Jan 18/05	<0.05	ug/L	
Prometryne	Jan 18/05	<0.25	ug/L	
Simazine	Jan 18/05	<1	ug/L	
THM (NOTE: show latest annual average)	Average Jan 18/05 May 05/05 Aug 25/05 Nov 29/05	66.0 29 106 72.4 56.4	ug/L ug/L ug/L ug/L ug/L	
Temephos	Jan 18/05	<10	ug/L	
Terbufos	Jan 18/05	<0.7	ug/L	
Tetrachloroethylene	Jan 18/05	<0.5	ug/L	
2,3,4,6-Tetrachlorophenol	Jan 18/05	<0.5	ug/L	
Triallate	Jan 18/05	<1	ug/L	
Trichloroethylene	Jan 18/05	<0.5	ug/L	
2,4,6-Trichlorophenol	Jan 18/05	<0.5	ug/L	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Jan 18/05	<1	ug/L	
Trifluralin	Jan 18/05	<1	ug/L	
Vinyl Chloride	Jan 18/05	<0.2	ug/L	

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	½ MAC VALUE	Date of Sample
Aldicarb	<5 (lab detection level)	ug/L	4.5 ug/L	Jan 18/05
Benzo(a)pyrene	<0.01 (lab detection level)	ug/L	0.005 ug/L	Jan 18/05
Tebufos	<0.7 (lab detection level)	ug/L	0.50 ug/L	Jan 18/05

Note! In all three cases above the analysis result value was less than the lab detection limit. However the lab detection limit is above the ½ MAC value.