

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	220000442
<b>Drinking-Water System Name:</b>	Sturgeon Falls Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2016 to December 31, 2016

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">                 Sturgeon Falls Water Treatment Plant                  11 Nipissing Street, Sturgeon Falls, ON             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve?                  Yes [ ] No [ ] Not Applicable [x]</p> <p>Number of Interested Authorities you report to:  <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?                  Yes [ ] No [ ] Not Applicable [x]</p>
--	---

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [ ] No [ ] Not Applicable [x]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- Public access/notice via the web**  
 **Public access/notice via Government Office**  
 **Public access/notice via a newspaper**  
 **Public access/notice via Public Request**  
 **Public access/notice via a Public Library**  
 **Public access/notice via other method:**

**Describe your Drinking-Water System**

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m<sup>3</sup>/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing for chemical assisted flocculation and sedimentation
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three dual media (anthracite/sand) gravity filters
- Continuous filtered turbidity monitoring for each filter
- Filtered water is directed through a chlorine contact tank, with filter-to-waste capability returning unchlorinated water to the Sturgeon River
- Chlorine gas addition points for primary disinfection located before filters (not used) and after filter-to-waste valve (normal addition point)
- One chlorine contact tank equipped with baffle walls, and discharge line to the underground reservoir
- Continuous Giardia log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition after the chlorine contact chamber for pH and alkalinity control
- Two cell in-ground treated water storage reservoir, equipped with valves to enhance flow through circulation
- A two-chamber high lift pump well located below the high lift pumping station
- Five vertical turbine type high lift pumps
- Post-chlorine gas addition to Distribution with continuous feed-back monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous feed-back monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator capable of servicing essential plant operations

**List all water treatment chemicals used over this reporting period**

- |   |
|---|
| <ul style="list-style-type: none"> <li>• Polyaluminum chloride</li> <li>• Specialty polymer</li> <li>• Limestone</li> <li>• Chlorine (gas)</li> <li>• Hydrated lime (calcium hydroxide)</li> <li>• Hydrofluosilicic acid (fluoride)</li> <li>• ENV 24P10 – distribution pipe corrosion control</li> <li>• ENV PYRO 50 - manganese dispersive sequestrant</li> </ul> |
|---|

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment
- Not Applicable

**Please provide a brief description and a breakdown of monetary expenses incurred**

Water Plant Material/Supplies/Rentals/Maintenance	\$59,644
Water Plant Process Chemicals	\$143,843
Water Quality Lab Testing	\$18,900
Consulting/Operator Training	\$8,727
Water Plant Utilities	\$224,672
Insurance	\$30,485
Labour	\$215,021
Electrical/Instrumentation	\$23,873

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
	Nil				

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Results CFU/100mL (min #)-(max #)	Range of Total Coliform Results CFU/100mL (min #)-(max #)
Raw	52	<5 – 40	40 – 410
Treated	52	0 – 0	0 – 0
Distribution	260	0 – 0	0 – 0

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity</b>	8760	Daily Average: 0.042 - 0.060 NTU
<b>Chlorine</b>	8760	Daily Average: 1.146 – 1.742 mg/L
<b>Fluoride</b>	8760	Daily Average: 0.58 - 0.66 mg/L

*NOTE: For continuous monitors use 8760 as the number of samples.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
7618-6QXP8Z (July 7/06)	Backwash SS	48 samples	21.3	mg/L (annual average)

**Summary of Inorganic and Organic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Fluoride	2016-11-02	0.5	mg/L	No
Nitrite (N)	2016-03-01	< 0.1	mg/L	No
	2016-06-20	< 0.1		No
	2016-09-15	< 0.1		No
	2016-11-02	< 0.1		No
Nitrate (N)	2016-03-01	0.2	mg/L	No
	2016-06-20	0.3		No
	2016-09-15	0.1		No
	2016-11-02	0.1		No
Nitrate + Nitrite (N)	2016-03-01	0.2	mg/L	No
	2016-06-20	0.3		No
	2016-09-15	0.1		No
	2016-11-02	0.1		No
Antimony	2016-11-02	< 0.0001	mg/L	No
Arsenic	2016-11-02	0.0004	mg/L	No
Barium	2016-11-02	0.012	mg/L	No
Boron	2016-11-02	< 0.005	mg/L	No
Cadmium	2016-11-02	< 0.00002	mg/L	No
Chromium	2016-11-02	< 0.002	mg/L	No
Lead	2016-11-02	0.00026	mg/L	No
Mercury	2016-11-02	< 0.00002	mg/L	No
Selenium	2016-11-02	< 0.001	mg/L	No
Sodium	2016-11-02	1.2	mg/L	No
Uranium	2016-11-02	< 0.00005	mg/L	No
Benzene	2016-11-02	< 0.5	µg/L	No
Carbon Tetrachloride	2016-11-02	< 0.2	µg/L	No
Dichlorobenzene, 1,2-	2016-11-02	< 0.1	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Dichlorobenzene, 1,4-	2016-11-02	< 0.2	µg/L	No
Dichloroethane, 1,2-	2016-11-02	< 0.1	µg/L	No
Dichloroethene, 1,1-	2016-11-02	< 0.1	µg/L	No
Dichloromethane (Methylene Chloride)	2016-11-02	< 0.3	µg/L	No
Monochlorobenzene (Chlorobenzene)	2016-11-02	< 0.2	µg/L	No
Tetrachloroethylene	2016-11-02	< 0.2	µg/L	No
Trichloroethylene	2016-11-02	< 0.1	µg/L	No
Vinyl Chloride	2016-11-02	< 0.2	µg/L	No
Chloroform	2016-03-01	46.4	µg/L	No
	2016-06-20	64.7		No
	2016-09-15	43.4		No
	2016-11-02	40.7		No
Bromodichloromethane	2016-03-01	2.1	µg/L	No
	2016-06-20	1.8		No
	2016-09-15	1.8		No
	2016-11-02	1.4		No
Dibromochloromethane	2016-03-01	< 0.1	µg/L	No
	2016-06-20	< 0.1		No
	2016-09-15	< 0.1		No
	2016-11-02	< 0.1		No
Bromoform	2016-03-01	< 0.1	µg/L	No
	2016-06-20	< 0.1		No
	2016-09-15	< 0.1		No
	2016-11-02	< 0.1		No
Total Trihalomethanes	2016-03-01	48.5	µg/L	No
	2016-06-20	66.5		No
	2016-09-15	45.2		No
	2016-11-02	42.2		No
Alachlor	2016-11-02	< 0.3	µg/L	No
Atrazine + Metabolites	2016-11-02	< 0.5	µg/L	No
Azinphos-methyl	2016-11-02	< 1	µg/L	No
Benzo(a)pyrene	2016-11-02	< 0.005	µg/L	No
Bromoxynil	2016-11-02	< 0.3	µg/L	No
Carbaryl	2016-11-02	< 3	µg/L	No
Carbofuran	2016-11-02	< 1	µg/L	No
Chlorpyrifos	2016-11-02	< 0.5	µg/L	No
Diazinon	2016-11-02	< 1	µg/L	No
Dicamba	2016-11-02	< 5	µg/L	No
Dichlorophenol, 2,4-	2016-11-02	< 0.1	µg/L	No
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	2016-11-02	< 5	µg/L	No
Diclofop-methyl	2016-11-02	< 0.5	µg/L	No
Dimethoate	2016-11-02	< 1	µg/L	No
Diquat	2016-11-02	< 5	µg/L	No
Diuron	2016-11-02	< 5	µg/L	No
Glyphosate	2016-11-02	< 1	µg/L	No
Malathion	2016-11-02	< 5	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	2016-11-02	< 0.00012	mg/L	No
Metolachlor	2016-11-02	< 3	µg/L	No
Metribuzin	2016-11-02	< 3	µg/L	No
Paraquat	2016-11-02	< 1	µg/L	No
Pentachlorophenol	2016-11-02	< 0.1	µg/L	No
Phorate	2016-11-02	< 0.3	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Picloram	2016-11-02	< 5	µg/L	No
Poly-Chlorinated Biphenyls (PCB's)	2016-11-02	< 0.05	µg/L	No
Prometryne	2016-11-02	< 0.1	µg/L	No
Simazine	2016-11-02	< 0.5	µg/L	No
Terbufos	2016-11-02	< 0.3	µg/L	No
Tetrachlorophenol, 2,3,4,6-	2016-11-02	< 0.1	µg/L	No
Triallate	2016-11-02	< 10	µg/L	No
Trichlorophenol 2,4,6-	2016-11-02	< 0.1	µg/L	No
Trifluralin	2016-11-02	< 0.5	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nil			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)