

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220000442
Drinking-Water System Name:	Sturgeon Falls Water Treatment Plant
Drinking-Water System Owner:	The Corporation of the Municipality of West Nipissing
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	January 1, 2018 to December 31, 2018

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 5px;"> Sturgeon Falls Water Treatment Plant 11 Nipissing Street, Sturgeon Falls, ON </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [] Not Applicable [x]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [] Not Applicable [x]</p>
---	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No [] Not Applicable [x]

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web**
 Public access/notice via Government Office
 Public access/notice via a newspaper
 Public access/notice via Public Request
 Public access/notice via a Public Library
 Public access/notice via other method:

Describe your Drinking-Water System

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m³/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing for chemical assisted flocculation and sedimentation
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three dual media (anthracite/sand) gravity filters
- Continuous filtered turbidity monitoring for each filter
- Filtered water is directed through a chlorine contact tank, with filter-to-waste capability returning unchlorinated water to the Sturgeon River
- Chlorine gas addition points for primary disinfection located before filters (not used) and after filter-to-waste valve (normal addition point)
- One chlorine contact tank equipped with baffle walls, and discharge line to the underground reservoir
- Continuous Giardia log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition after the chlorine contact chamber for pH and alkalinity control
- Two cell in-ground treated water storage reservoir, equipped with valves to enhance flow through circulation
- A two-chamber high lift pump well located below the high lift pumping station
- Five vertical turbine type high lift pumps
- Post-chlorine gas addition to Distribution with continuous feed-back monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous feed-back monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator capable of servicing essential plant operations

List all water treatment chemicals used over this reporting period

- Polyaluminum chloride – for coagulation
- Specialty polymer – for flocculation
- Limestone – for pH adjustment and coagulation
- Chlorine (gas) – for disinfection
- Hydrated lime (calcium hydroxide) – for pH alkalinity adjustment
- Hydrofluosilicic acid – for fluoridation
- ENV 24P10 – for distribution pipe corrosion control
- ENV PYRO 50 – for manganese dispersive sequestration

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment
- Not Applicable

Please provide a brief description and a breakdown of monetary expenses incurred

Water Plant Material/Supplies/Rentals/Maintenance	\$66,490
Water Plant Process Chemicals	\$141,759
Water Quality Lab Testing	\$17,527
Consulting/Operator Training	\$11,078
Water Plant Utilities	\$230,119
Insurance	\$31,146
Labour	\$217,661
Electrical/Instrumentation	\$4,271

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
	Nil				

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Results CFU/100mL (min #)-(max #)	Range of Total Coliform Results CFU/100mL (min #)-(max #)
Raw	52	<10 – 70	70 – >2000
Treated	52	0 – 0	0 – 0
Distribution	260	0 – 0	0 – 0

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Daily Average: 0.05 - 0.98 NTU
Chlorine	8760	Daily Average: 0.91 - 1.74 mg/L
Fluoride	8760	Daily Average: 0.02 - 0.80 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
7618-6QXP8Z (July 7/06)	Backwash SS	45 samples	9.1	mg/L (annual average)

Summary of Inorganic and Organic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Fluoride	2018-09-24	0.6	mg/L	No
Nitrite (N)	2018-01-30	< 0.1	mg/L	No
	2018-04-10	< 0.1		No
	2018-07-03	< 0.1		No
	2018-09-24	< 0.1		No
	2018-12-17	<0.1		No
Nitrate (N)	2018-01-30	<0.1	mg/L	No
	2018-04-10	0.1		No
	2018-07-03	<0.1		No
	2018-09-24	<0.1		No
	2018-12-17	<0.1		No
Haloacetic Acids (Running Annual Averages)	2018-01-30	23.9 (43.8)	µg/L	
	2018-04-10	22.2 (39.2)		
	2018-07-03	29.3		
	2018-09-24	33.7 (29.1)		
	2018-12-17	24.8 (25.6)		
Antimony	2018-09-24	< 0.0001	mg/L	No
Arsenic	2018-09-24	0.0003	mg/L	No
Barium	2018-09-24	0.009	mg/L	No
Boron	2018-09-24	<0.005	mg/L	No
Cadmium	2018-09-24	< 0.000015	mg/L	No
Chromium	2018-09-24	< 0.002	mg/L	No
Lead	2018-09-24	0.00026	mg/L	No
Mercury	2018-09-24	< 0.00002	mg/L	No
Selenium	2018-09-24	< 0.001	mg/L	No
Sodium	2018-09-24	1.4	mg/L	No
Uranium	2018-09-24	< 0.00005	mg/L	No
Benzene	2018-09-24	< 0.5	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Carbon Tetrachloride	2018-09-24	< 0.2	µg/L	No
Dichlorobenzene, 1,2-	2018-09-24	< 0.5	µg/L	No
Dichlorobenzene, 1,4-	2018-09-24	< 0.5	µg/L	No
Dichloroethane, 1,2-	2018-09-24	< 0.5	µg/L	No
Dichloroethene, 1,1-	2018-09-24	< 0.5	µg/L	No
Dichloromethane (Methylene Chloride)	2018-09-24	< 0.3	µg/L	No
Monochlorobenzene (Chlorobenzene)	2018-09-24	< 0.5	µg/L	No
Tetrachloroethylene	2018-09-24	< 0.5	µg/L	No
Trichloroethylene	2018-09-24	< 0.5	µg/L	No
Vinyl Chloride	2018-09-24	< 0.5	µg/L	No
Chloroform	2018-01-30	33.1	µg/L	No
	2018-04-10	26.8		No
	2018-07-03	86.6		No
	2018-09-24	37		No
	2018-12-17	35.5		No
Bromodichloromethane	2018-01-30	1.8	µg/L	No
	2018-04-10	1.3		No
	2018-07-03	3.4		No
	2018-09-24	2		No
	2018-12-17	1.3		No
Dibromochloromethane	2018-01-30	< 0.1	µg/L	No
	2018-04-10	< 0.1		No
	2018-07-03	< 0.1		No
	2018-09-24	< 2		No
	2018-12-17	< 0.1		No
Bromoform	2018-01-30	< 0.1	µg/L	No
	2018-04-10	< 0.1		No
	2018-07-03	< 0.1		No
	2018-09-24	< 5		No
	2018-12-17	< 0.1		No
Total Trihalomethanes (Running Annual Averages)	2018-01-30	33.1 (52.4)	µg/L	No
	2018-04-10	28.1 (44.2)		No
	2018-07-03	90.0		No
	2018-09-24	39.0 (41.3)		No
	2018-12-17	36.9 (41.1)		No
Atrazine + Metabolites	2018-09-24	< 0.5	µg/L	No
Azinphos-methyl	2018-09-24	< 1	µg/L	No
Benzo(a)pyrene	2018-09-24	< 0.005	µg/L	No
Bromoxynil	2018-09-24	< 0.3	µg/L	No
Carbaryl	2018-09-24	< 3	µg/L	No
Carbofuran	2018-09-24	< 1	µg/L	No
Chlorpyrifos	2018-09-24	< 0.5	µg/L	No
Diazinon	2018-09-24	< 1	µg/L	No
Dicamba	2018-09-24	< 5	µg/L	No
Dichlorophenol, 2,4-	2018-09-24	< 0.1	µg/L	No
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	2018-09-24	< 5	µg/L	No
Diclofop-methyl	2018-09-24	< 0.5	µg/L	No
Dimethoate	2018-09-24	< 1	µg/L	No
Diquat	2018-09-24	< 5	µg/L	No
Diuron	2018-09-24	< 5	µg/L	No
Glyphosate	2018-09-24	< 25	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Malathion	2018-09-24	< 5	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	2018-09-24	< 10	mg/L	No
Metolachlor	2018-09-24	< 3	µg/L	No
Metribuzin	2018-09-24	< 3	µg/L	No
Paraquat	2018-09-24	< 1	µg/L	No
Pentachlorophenol	2018-09-24	< 0.1	µg/L	No
Phorate	2018-09-24	< 0.3	µg/L	No
Picloram	2018-09-24	< 5	µg/L	No
Poly-Chlorinated Biphenyls (PCB's)	2018-09-24	< 0.05	µg/L	No
Prometryne	2018-09-24	< 0.1	µg/L	No
Simazine	2018-09-24	< 0.5	µg/L	No
Terbufos	2018-09-24	< 0.3	µg/L	No
Tetrachlorophenol, 2,3,4,6-	2018-09-24	< 0.1	µg/L	No
Triallate	2018-09-24	< 10	µg/L	No
Trichlorophenol 2,4,6-	2018-09-24	< 0.1	µg/L	No
Trifluralin	2018-09-24	< 0.5	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nil			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)