

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	220000442
<b>Drinking-Water System Name:</b>	Sturgeon Falls Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2006 to December 31, 2006

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Sturgeon Falls Water Treatment Plant 11 Nipissing Street Sturgeon Falls ON P2B 1J4</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
n/a	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water? Yes [ ] No [ ]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m<sup>3</sup>/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing; flocculating chemicals consist of powdered limestone and aluminum sulphate, and activated silica as a coagulant aid
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three dual media (anthracite/sand) gravity filters
- Continuous filtered turbidity monitoring for each filter
- Filtered effluent discharge to the post-filtration chlorine contact tanks with optional filter-to-waste capability return to the Sturgeon River (unchlorinated)
- Chlorine gas addition points located before filters and after filter-to-waste valve
- One chlorine contact tank equipped with baffle walls, with an overflow pipe and discharge line to the underground reservoir
- Continuous Giardia Log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition after the chlorine contact chamber for pH and alkalinity control
- Two cell in-ground treated water storage reservoir, equipped with valves to enhance flow through circulation
- A two-chamber high lift pump well located below the high lift pumping station
- Five vertical turbine type high lift pumps
- Post-chlorine gas addition to Distribution with continuous feed-back monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous feed-back monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator servicing entire plant

### List all water treatment chemicals used over this reporting period

- Alum (aluminum sulphate)
- Activated silica (sodium silicate and alum)
- Chlorine (gas)
- Limestone
- Hydrated lime (calcium hydroxide)
- Hydrofluosilicic acid (fluoride)

### Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

### Please provide a brief description and a breakdown of monetary expenses incurred

Water Plant Material/Supplies/Rentals	\$14 000
Water Plant Equipment Maintenance/Repairs	\$25 000
Water Plant Process Chemicals	\$44 000
Water Quality Lab Testing	\$9 000
Consulting/Operator Training	\$59 000
Water Plant Utilities	\$116 000
Water Distribution Materials/Supplies/Repairs	\$70 000

### Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
06-06-04	Low chlorine residual to Distribution (false readings)	<0.20	mg/L	<ul style="list-style-type: none"> <li>• False readings on pump starts showing chlorine residual dropping below 0.20mg/L</li> <li>• MOE and Health Unit notified</li> <li>• Health Unit requested 8 distribution samples be collected and tested</li> <li>• All samples had adequate chlorine residual and negative bacti test results</li> <li>• Chlorination at the Water Treatment Plant was always maintained</li> <li>• The post chlorinator was shut off on June 5 for a test, and the residual chlorine dropped to 0.90mg/L, the low spikes for the pump starts were non-representative</li> <li>• AWQI 64600</li> </ul>	06-06-06
06-07-12	Total Coliform in Distribution sample	6	CFU/100mL	<ul style="list-style-type: none"> <li>• Sampling bleed at end of Champagne was submerged in ditch</li> <li>• Pipe was thoroughly cleaned and disinfected with alcohol before re-sampling</li> <li>• Sample also collected at closest hydrant</li> <li>• Both samples were negative for bacti</li> <li>• Double check valve added to bleed</li> <li>• AWQI 65785</li> </ul>	06-07-17

# Drinking-Water Systems Regulation O. Reg. 170/03

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
06-07-20	Total Coliform in Distribution sample	7	CFU/100mL	<ul style="list-style-type: none"> <li>• Sample was collected from continuous bleed off of hydrant at end of Cache Bay Road</li> <li>• Re-sampled and re-tested; results were negative for bacti</li> <li>• Bleed already equipped with air gap protection</li> <li>• AWQI 66162</li> </ul>	06-07-22
06-08-12	Total Coliform in Distribution sample	1	CFU/100mL	<ul style="list-style-type: none"> <li>• Watermain was closed and isolated for high pressure cleaning on August 9 and 10</li> <li>• Affected residences were under boil water advisory when water service is restored</li> <li>• Samples collected on August 11 after the cleaning had 1 CFU/100mL Total Coliform</li> <li>• MOE and Health Unit notified; boil water stayed in effect</li> <li>• Samples collected August 12 were negative</li> <li>• Boil water advisory was lifted August 13.</li> <li>• AWQI 66944</li> </ul>	05-09-06
06-10-30	Low chlorine residual in Distribution	0.0	mg/L	<ul style="list-style-type: none"> <li>• Dirty water complaint at 139 John Street</li> <li>• Flushed hydrant at John and Arthur, but dirty water was not clearing</li> <li>• Discovered watermain valve at John and Arthur was closed</li> <li>• Opened valve and</li> <li>• Note, sealants on the hydrant joints are made of lead</li> <li>• Re-sampled according to protocol by collecting running water</li> <li>• Re-sampled results were non-detect (&lt;0.001mg/L)</li> <li>• AWQI 60646</li> </ul>	05-11-08

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw</b>	52	10 - 1320	< 5 - 40	0	
<b>Treated</b>	52	0 - 0	0 - 0	11	0 - 1
<b>Distribution</b>	212	0 - 0	0 - 7	14	0 - 52

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity</b>	8760	Daily Average 0.028 - 0.220 NTU Instantaneous 0.028 – 4.647 NTU
<b>Chlorine</b>	8760	Daily Average 0.64 - 1.63 mg/L Instantaneous 0.00 – 2.73 mg/L
<b>Fluoride</b> (If the DWS provides fluoridation)	8760	Daily Average 0.02 - 0.80 mg/L Instantaneous 0.00 – 2.00 mg/L

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
7618-6QXP8Z (July 7/06)	Backwash SS	monthly	16.7	mg/L (annual average)

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	2006-10-11	< 0.0001	mg/L	no
Arsenic	2006-10-11	0.001	mg/L	no
Barium	2006-10-11	0.012	mg/L	no
Boron	2006-10-11	< 0.005	mg/L	no
Cadmium	2006-10-11	< 0.0001	mg/L	no
Chromium	2006-10-11	< 0.002	mg/L	no
Lead	2006-10-11	0.0003	mg/L	no
Mercury	2006-10-11	< 0.0001	mg/L	no
Selenium	2006-10-11	0.0018	mg/L	no
Sodium	2006-10-11	1.4	mg/L	no
Uranium	2006-10-11	< 0.00005	mg/L	no
Fluoride	2006-10-11	0.6	mg/L	no
Nitrite	2006-02-15	< 0.1	mg/L	no
	2006-05-16	< 0.1		
	2006-08-24	< 0.1		
	2006-10-11	< 0.1		
Nitrate	2006-02-15	0.2	mg/L	no
	2006-05-16	0.1		
	2006-08-24	0.1		
	2006-10-11	0.1		

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	2006-10-11	< 0.3	µg/L	no
Aldicarb	2006-10-11	< 3	µg/L	no
Aldrin + Dieldrin	2006-10-11	< 0.02	µg/L	no
Atrazine + N-dealkylated metabolites	2006-10-11	< 0.5	µg/L	no
Azinphos-methyl	2006-10-11	< 1	µg/L	no
Bendiocarb	2006-10-11	< 3	µg/L	no
Benzene	2006-10-11	< 0.5	µg/L	no
Benzo(a)pyrene	2006-10-11	< 0.005	µg/L	no
Bromoxynil	2006-10-11	< 0.3	µg/L	no
Carbaryl	2006-10-11	< 3	µg/L	no
Carbofuran	2006-10-11	< 1	µg/L	no
Carbon Tetrachloride	2006-10-11	< 0.2	µg/L	no
Chlordane (Total)	2006-10-11	< 0.04	µg/L	no
Chlorpyrifos	2006-10-11	< 0.5	µg/L	no
Cyanazine	2006-10-11	< 0.5	µg/L	no
Diazinon	2006-10-11	< 1	µg/L	no
Dicamba	2006-10-11	< 5	µg/L	no
1,2-Dichlorobenzene	2006-10-11	< 0.1	µg/L	no
1,4-Dichlorobenzene	2006-10-11	< 0.2	µg/L	no
Dichlorodiphenyltrichloroethane (DDT) + metabolites	2006-10-11	< 0.1	µg/L	no
1,2-Dichloroethane	2006-10-11	< 0.1	µg/L	no
1,1-Dichloroethylene (vinylidene chloride)	2006-10-11	< 0.1	µg/L	no
Dichloromethane	2006-10-11	< 0.3	µg/L	no
2-4 Dichlorophenol	2006-10-11	< 0.1	µg/L	no
2,4-Dichlorophenoxy acetic acid (2,4-D)	2006-10-11	< 5	µg/L	no
Diclofop-methyl	2006-10-11	< 0.4	µg/L	no
Dimethoate	2006-10-11	< 1	µg/L	no
Dinoseb	2006-10-11	< 0.5	µg/L	no
Diquat	2006-10-11	< 5	µg/L	no
Diuron	2006-10-11	< 5	µg/L	no
Glyphosate	2006-10-11	< 25	µg/L	no
Heptachlor + Heptachlor Epoxide	2006-10-11	< 0.1	µg/L	no
Lindane (Total)	2006-10-11	< 0.1	µg/L	no
Malathion	2006-10-11	< 5	µg/L	no
Methoxychlor	2006-10-11	< 0.1	µg/L	no
Metolachlor	2006-10-11	< 3	µg/L	no
Metribuzin	2006-10-11	< 3	µg/L	no
Monochlorobenzene	2006-10-11	< 0.2	µg/L	no
Paraquat	2006-10-11	< 1	µg/L	no
Parathion	2006-10-11	< 3	µg/L	no
Pentachlorophenol	2006-10-11	< 0.1	µg/L	no
Phorate	2006-10-11	< 0.3	µg/L	no
Picloram	2006-10-11	< 5	µg/L	no
Polychlorinated Biphenyls(PCB)	2006-10-11	< 0.05	µg/L	no
Prometryne	2006-10-11	< 0.1	µg/L	no
Simazine	2006-10-11	< 0.5	µg/L	no

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
THM (NOTE: show latest annual average)	2006-02-15	26.2	µg/L	no
	2006-05-16	96.7		
	2006-08-24	99.4		
	2006-10-11	61.5		
Temephos	2006-10-11	< 10	µg/L	no
Terbufos	2006-10-11	< 0.3	µg/L	no
Tetrachloroethylene	2006-10-11	< 0.2	µg/L	no
2,3,4,6-Tetrachlorophenol	2006-10-11	< 0.1	µg/L	no
Triallate	2006-10-11	< 10	µg/L	no
Trichloroethylene	2006-10-11	< 0.1	µg/L	no
2,4,6-Trichlorophenol	2006-10-11	< 0.1	µg/L	no
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	2006-10-11	< 10	µg/L	no
Trifluralin	2006-10-11	< 0.5	µg/L	no
Vinyl Chloride	2006-10-11	< 0.2	µg/L	no

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

**(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)**