

**O. Reg. 170 SECTION 11 ANNUAL REPORT**
**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	210000951
<b>Drinking-Water System Name:</b>	Verner WTP
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	Jan 01, 2015 to Dec 31, 2015

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [<input checked="" type="checkbox"/>]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Municipality of West Nipissing Sturgeon Falls Water Treatment Plant 11 Nipissing Street Sturgeon Falls, Ontario P2B 1J4</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
NA	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes [ ] No [ ]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web <http://www.westnipissingouest.ca/pop/dep-utilities.html>

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library copies placed at West Nipissing Library

Public access/notice via other method

### Describe your Drinking-Water System

The Verner WTP was originally commissioned in 1975 and underwent major regulatory upgrades in 2005 which included replacement of all chemical feed system equipment and tanks; replacement of the plant instrumentation and controls; installation of a UV system for primary disinfection; installation of piping and valves to provide treatment-to-waste functionality; new raw water and treated water magnetic flow meters; and the installation of a 125 kW standby diesel generator. Also radio telemetry equipment was installed at the elevated storage tank to permit treatment plant-elevated tank communication and control.

The Verner Municipal Water System is a surface water system that draws water from the Veuve River which is part of the Lake Nipissing watershed. The intake structure is located 12 km upstream of Lake Nipissing and 48 km downstream of the source. The Veuve River, upstream from the intake, has a catchment area of approximately 92,000 ha. This area is well developed and includes: Hwy 17 corridor; CPR railway tracks; housing and cottage development.

The water treatment plant's intake facility consists of an intake structure located 5 m below the low river level, connected to a raw water wet well by a 42.7 m long, 250 mm ductile iron pipe. The intake structure is approximately 20 m from the riverbank.

The Verner Water Treatment Plant (WTP) is a conventional treatment facility, with a designed capacity of 1059 m<sup>3</sup>/d. Conventional treatment is comprised of coagulation, flocculation, sedimentation & dual media rapid sand filtration, primary disinfection & secondary disinfection. Furthermore, disinfection is achieved through the use of chlorine dioxide, UV and chlorine gas. Chemically assisted filtration is through the use of an "Ecodyne Graver Monoplant" package treatment plant.

The Ecodyne Graver Monoplant package treatment plant, consists of a Mixing Zone; Flocculation Zone; Settling Compartment and flock barriers; Blowdown valve and rapid flow by gravity sand and anthracite filters.

Chemical treatment includes the addition of polymer, aluminum sulfate, pre and post soda ash, chlorine for disinfection and chlorine dioxide for iron and manganese removal to control taste and odour.

There are four (4) below grade clear wells connected in series having a total area, total capacity and useable capacity of 134 m<sup>2</sup>, 269 m<sup>3</sup> and 234 m<sup>3</sup> respectively. The high lift pumping station has a firm capacity of 1,090 m<sup>3</sup>/d with three (3) identical vertical turbine high lift pumps each having a capacity of 545 m<sup>3</sup>/d at a TDH of 53.3 m.

Standby emergency power is supplied at this plant by a 125 kW standby diesel generator with automatic switchover controls installed as part of the 2005 plant upgrades

The Verner Water Distribution System consists of approximately eight kilometers of watermain. The system includes an off site water storage facility located on the west side of

## O. Reg. 170 SECTION 11 ANNUAL REPORT

Dubeau Street (192 m north of the intersection of Dubeau Street and Vercheres Avenue). The facility is a steel and concrete elevated storage tank, having a total storage capacity of 568 m<sup>3</sup> and about 40 m above ground equipped with low level alarm and an overflow. The system has approximately 50 hydrants, and serves approximately 1,100 consumers. The Distribution system is classified as a Class I system.

**List all water treatment chemicals used over this reporting period**

Chlorine Gas  
 Sodium Chlorite  
 Sodium Carbonate  
 Aluminum Sulfate (ALUM)  
 Magnafloc LT20 Poly Acrylamide Polymer  
 Chlorine dioxide is produced on site by combining Chlorine solution with sodium chlorite.

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Description of major repairs, equipment replacement or capital improvements**

Drinking Quality Management Standard Audit \$2,404  
 Drinking Quality Management Standard Audit \$1,270  
 Replace CLO2 sensor & transmitter, site visit and calibrate \$3,395  
 Chlorine system parts \$1,711

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date	AWQI#
N/A						

**Microbiological testing done under section 8-2 during this reporting period.**

## O. Reg. 170 SECTION 11 ANNUAL REPORT

	Number of EC & TC Samples	Range of E.Coli Results (min #)-(max #)	Range of Total Coli form Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	52	0-540	0-46000	NA	NA
Treated	57	0 - 0	0 - 0	52	0 - 2
Distribution	154	0 - 0	0 - 0	52	0 - 1

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

### Filter Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Post Filter Turbidity	142	0.10– 0.26 NTU

*NOTE: For continuous monitors use 8760 as the number of samples.*

### POE Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/A	N/A
Free Chlorine	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples.*

### Distribution Grabs

	Number of Grab Samples	Range of Results (min #)-(max #)
Free Chlorine	328	0.30 – 2.15 mg/L

*NOTE: For continuous monitors use 8760 as the number of samples.*

### Filter On-line Continuous Analyzers

	Number of Samples	Range of Results (min #)-(max #)
Post Filter Turbidity	8760	0.02– 2.0 NTU

*NOTE: For continuous monitors use 8760 as the number of samples.*

### POE On-line Continuous Analyzers

POE	Number of Samples	Range of Results (min #)-(max #)
Free Chlorine	8760	0.0 – 5.0 mg/L

*NOTE: For continuous monitors use 8760 as the number of samples.*

**O. Reg. 170 SECTION 11 ANNUAL REPORT**

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date of legal instrument issued	Parameter	Sampling Frequency	Range of Result	Unit of Measure
<b>Municipal Drinking Water Licence 202-101 issued May 25, 2011</b>	<b>UV Intensity Design dose 40mj/cm2 = Min 12.7 W/m2 &amp; Min UVT 65.3% &amp; Max flow of 12.2 L/ OR Min 18.2 W/m2 &amp; Min UVT of 72.2% &amp; Max flow of 12.</b>	<b>continuous when units operating</b>	<b>plant shut down interlock activates if dosage &lt;13 W/m<sup>2</sup></b>	<b>W/m<sup>2</sup></b>
	<b>Flow Rate</b>	<b>continuous</b>	<b>min 297 – max 800.9 (4.36 L/s – 11.52 L/s)</b>	<b>m<sup>3</sup>/d</b>
	<b>UV Transmittance</b>	<b>monthly</b>	<b>min 87- max 88</b>	<b>% UVT</b>
	<b>UV Sensor &gt;/ = 0.8&amp; &lt;/ = 1.2</b>	<b>annually</b>	<b>Calibration Ratio Range VN 004 0.96 – 1.01 VN 0028 0.95 – 1.01</b>	<b>calibration ratio</b>
	<b>UV Lamp Status</b>	<b>continuous</b>	<b>plant shut down interlock on lamp failure</b>	<b>on <u>or</u> off</b>

Summary of Inorganic parameters tested during this reporting period or the most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	<b>17 Feb 15</b>	<b>0.09</b>	<b>ug/L</b>	<b>No</b>
<b>Arsenic</b>	<b>17 Feb 15</b>	<b>0.3</b>	<b>ug/L</b>	<b>No</b>
<b>Barium</b>	<b>17 Feb 15</b>	<b>14.5</b>	<b>ug/L</b>	<b>No</b>
<b>Boron</b>	<b>17 Feb 15</b>	<b>6.6</b>	<b>ug/L</b>	<b>No</b>
<b>Cadmium</b>	<b>17 Feb 15</b>	<b>0.010</b>	<b>ug/L</b>	<b>No</b>
<b>Chromium</b>	<b>17 Feb 15</b>	<b>0.06</b>	<b>ug/L</b>	<b>No</b>
<b>Mercury</b>	<b>17 Feb 15</b>	<b>0.03</b>	<b>mg/L</b>	<b>No</b>
<b>Selenium</b>	<b>17 Feb 15</b>	<b>&lt;1</b>	<b>ug/L</b>	<b>No</b>
<b>Sodium</b>	<b>22 Feb 2012</b>	<b>46</b>	<b>mg/L</b>	<b>YES –Notification to the MOH was made in 2008; Sampling takes place every 5 year. Notifications which are required every 57 months will be due during the next round of sampling in 2017.</b>
<b>Uranium</b>	<b>17 Feb 15</b>	<b>0.003</b>	<b>ug/L</b>	<b>No</b>
<b>Fluoride</b>	<b>22 Mar 2011</b>	<b>&lt;0.1</b>	<b>mg/L</b>	<b>No</b>

**O. Reg. 170 SECTION 11 ANNUAL REPORT**

<b>Nitrite</b>	17 Feb 2015	<0.003	mg/L	No
	25 May 2015	<0.003	mg/L	No
	08 Sep 2015	<0.003	mg/L	No
	21 Dec 2015	<0.003	mg/L	No
<b>Nitrate</b>	17 Feb 2015	0.241	mg/L	No
	25 May 2015	0.048	mg/L	No
	08 Sep 2015	0.049	mg/L	No
	21 Dec 2015	0.077	mg/L	No

Summary of lead testing under **O. Reg. 170/03** Schedule 15.1 during this reporting period (applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Round 1 Dec 15 2014 to Apr 15 2015	Number of Lead Samples	Number of Adverse Results	Number of Hydrants Sampled	Range of Lead Samples (ug/L)		Range of PH Sample Results		Range of Alkalinity Sample Results (mg/L as CaCO <sub>3</sub> )	
				MIN	MAX	MIN	MAX	MIN	MAX
<b>Distribution</b>	0	0	2	N/A	N/A	6.87	6.94	48.9	57.6
<b>Non-Residential</b>	0	0	N/A	N/A	N/A	N/A	N/A	NA	NA
<b>Residential</b>	0	0	N/A	N/A	N/A	N/A	N/A	NA	NA
Round 2 June 15 2015 to Oct 15 2015	Number of Lead Samples	Number of Adverse Results	Number of Hydrants Sampled	Range of Lead Samples (ug/L)		Range of PH Sample Results		Range of Alkalinity Sample Results (mg/L as CaCO <sub>3</sub> )	
				MIN	MAX	MIN	MAX	MIN	MAX
<b>Distribution</b>	0	0	2	N/A	N/A	6.46	6.55	66.8	68.2
<b>Non-Residential</b>	0	0	N/A	N/A	N/A	N/A	N/A	NA	NA
<b>Residential</b>	0	0	N/A	N/A	N/A	N/A	N/A	NA	NA

**Summary of Organic parameters sampled during this reporting period or the most recent**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	17 Feb 15	<0.02	ug/L	No
Aldicarb	17 Feb 15	<0.01	ug/L	No
Aldrin	17 Feb 15	<0.01	ug/L	No
Aldrin + Dieldrin	17 Feb 15	<0.01	ug/L	No
Atrazine	17 Feb 15	<0.01	ug/L	No
Atrazine + Desethyl-atrazine	17 Feb 15	<0.01	ug/L	No
Atrazine + N-dealkylated metabolites	17 Feb 15	<0.01	ug/L	No
Azinphos-methyl Guthion	17 Feb 15	<0.02	ug/L	No
Bendiocarb	17 Feb 15	<0.01	ug/L	No
Benzene	17 Feb 15	<0.32	ug/L	No
Benzo(a)pyrene	17 Feb 15	<0.004	ug/L	No
Bromoxynil	17 Feb 15	<0.33	ug/L	No
Carbaryl	17 Feb 15	<0.01	ug/L	No
Carbofuran	17 Feb 15	<0.01	ug/L	No
Carbon Tetrachloride	17 Feb 15	<0.16	ug/L	No
g-Clorodane	17 Feb 15	<0.01	ug/L	No
a-Clorodane	17 Feb 15	<0.01	ug/L	No
Chlordane (Total)	17 Feb 15	<0.01	ug/L	No
Chlorpyrifos	17 Feb 15	<0.02	ug/L	No
Cyanazine	17 Feb 15	<0.03	ug/L	No
Desethyl-atrazine	17 Feb 15	<0.01	ug/L	No
Diazinon	17 Feb 15	<0.02	ug/L	No
Dicamba	17 Feb 15	<0.20	ug/L	No
Dieldrin	17 Feb 15	<0.01	ug/L	No
1,2-Dichlorobenzene	17 Feb 15	<0.41	ug/L	No
1,4-Dichlorobenzene	17 Feb 15	<0.36	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	17 Feb 15	<0.01	ug/L	No
1,2-Dichloroethane	17 Feb 15	<0.35	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	17 Feb 15	<0.33	ug/L	No
Dichloromethane (Methylene Chloride)	17 Feb 15	<0.35	ug/L	No
2-4 Dichlorophenol	17 Feb 15	<0.15	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	17 Feb 15	<0.19	ug/L	No
Diclofop-methyl	17 Feb 15	<0.40	ug/L	No
Dimethoate	17 Feb 15	<0.03	ug/L	No
Dinoseb	17 Feb 15	<0.36	ug/L	No

**O. Reg. 170 SECTION 11 ANNUAL REPORT**

Diquat	17 Feb 15	<1	ug/L	No
Diuron	17 Feb 15	<0.03	ug/L	No
Glyphosate	17 Feb 15	<1	ug/L	No
Heptachlor	17 Feb 15	<0.01	ug/L	No
Heptachlor Epoxide	17 Feb 15	<0.01	ug/L	No
Heptachlor + Heptachlor Epoxide	17 Feb 15	<0.01	ug/L	No
Lindane (Total)	17 Feb 15	<0.01	ug/L	No
Malathion	17 Feb 15	<0.02	ug/L	No
Methoxychlor	17 Feb 15	<0.01	ug/L	No
Metolachlor	17 Feb 15	<0.01	ug/L	No
Metribuzin	17 Feb 15	<0.02	ug/L	No
Monochlorobenzene	17 Feb 15	<0.3	ug/L	No
Oxychlorane	17 Feb 15	<0.01	ug/L	No
Paraquat	17 Feb 15	<1	ug/L	No
Parathion	17 Feb 15	<0.02	ug/L	No
Pentachlorophenol	17 Feb 15	<0.15	ug/L	No
Phorate	17 Feb 15	<0.01	ug/L	No
Picloram	17 Feb 15	<1	ug/L	No
Polychlorinated Biphenyls(PCB)	17 Feb 15	<0.04	ug/L	No
p,p-DDE	17 Feb 15	<0.01	ug/L	No
p,p-DDD	17 Feb 15	<0.01	ug/L	No
o,p-DDT	17 Feb 15	<0.01	ug/L	No
p,p-DDT	17 Feb 15	<0.01	ug/L	No
Prometryne	17 Feb 15	<0.03	ug/L	No
Simazine	17 Feb 15	<0.01	ug/L	No
Temephos	17 Feb 15	<0.01	ug/L	No
Terbufos	17 Feb 15	<0.01	ug/L	No
Tetrachloroethylene	17 Feb 15	<0.35	ug/L	No
2,3,4,6-Tetrachlorophenol	17 Feb 15	<0.20	ug/L	No
Triallate	17 Feb 15	<0.01	ug/L	No
Trichloroethylene	17 Feb 15	<0.44	ug/L	No
2,4,6-Trichlorophenol	17 Feb 15	<0.25	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	17 Feb 15	<0.22	ug/L	No
Trifluralin	17 Feb 15	<0.02	ug/L	No
Vinyl Chloride	17 Feb 15	<0.17		



**O. Reg. 170 SECTION 11 ANNUAL REPORT**

<b>THM</b> Result marked with * not used in calculating the annual average. The regulation requires that the highest result from each quarter be used to calculate the average	<b>1 st Quarter Result Value</b>	<b>2 nd Quarter Result Value</b>	<b>3 rd Quarter Result Value</b>	<b>4th Quarter Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
<b>Date Sampled</b>	<b>17 Feb 15</b>	<b>27 May15</b>	<b>08 Sep 15</b>	<b>21 Dec 15</b>		
<b>Bromodichloromethane</b>	<b>1.7</b>	<b>2.1</b>	<b>3.6</b>	<b>1.4</b>	<b>ug/L</b>	<b>No</b>
<b>Bromoform</b>	<b>&lt;0.34</b>	<b>&lt;0.34</b>	<b>&lt;0.34</b>	<b>&lt;0.34</b>	<b>ug/L</b>	<b>No</b>
<b>Chloroform</b>	<b>3731</b>	<b>61</b>	<b>43</b>	<b>64</b>	<b>ug/L</b>	<b>No</b>
<b>Dibromochloromethane</b>	<b>&lt;0.37</b>	<b>&lt;0.37</b>	<b>&lt;0.37</b>	<b>&lt;0.37</b>	<b>ug/L</b>	<b>No</b>
<b>Total Trihalomethanes</b>	<b>32</b>	<b>64</b>	<b>46</b>	<b>65</b>	<b>ug/L</b>	<b>No</b>
<b>Total Trihalomethanes 4 Quarter Average</b>				<b>51.75</b>	<b>ug/L</b>	<b>No</b>

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

<b>Parameter</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>½ MAC VALUE</b>	<b>MAC Value</b>	<b>Date of Sample</b>
<b>Sodium</b>	<b>46</b>	<b>mg/L</b>	<b>10</b>	<b>20</b>	<b>22 Feb 12</b>
<b>THM</b>	<b>64</b>	<b>ug/L</b>	<b>50</b>	<b>100</b>	<b>27 May 15</b>
<b>THM</b>	<b>55</b>	<b>ug/L</b>	<b>50</b>	<b>100</b>	<b>21 Dec 15</b>