

**Part III Form 2  
Section 11. ANNUAL REPORT.**

<b>Drinking-Water System Number:</b>	220000442
<b>Drinking-Water System Name:</b>	Sturgeon Falls Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of West Nipissing
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2019 to December 31, 2019

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [x]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; margin-top: 5px;">                 Sturgeon Falls Water Treatment Plant                  11 Nipissing Street, Sturgeon Falls, ON             </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve?                  Yes [ ] No [ ] Not Applicable [x]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?                  Yes [ ] No [ ] Not Applicable [x]</p>
---	--

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [ ] No [ ] Not Applicable [x]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

**[x] Public access/notice via the web**

**Describe your Drinking-Water System**

The Sturgeon Falls WTP commissioned in 1991, consists of a full surface water treatment facility, with a design capacity of 14 200 m<sup>3</sup>/day, drawing water from the Sturgeon River.

The process consists of:

- Intake from the Sturgeon River, equipped with manually removable screens
- Four vertical turbine raw water pumps
- Two up-flow pre-treatment tanks for flash mixing for chemical assisted flocculation and sedimentation
- Four sets of three-cells-in-series flocculation tanks
- Two rectangular settling tanks, each with an inclined plate settling system
- Three anthracite/sand gravity filters, each with continuous turbidity monitoring
- Chlorine gas for primary disinfection
- One chlorine contact tank equipped with baffle walls, and discharge line to the underground reservoir
- Continuous Giardia log removal calculations to monitor adequacy of disinfection
- Hydrated lime (calcium hydroxide) addition for pH and alkalinity control
- Two cell in-ground storage reservoir
- A two-chamber clear well
- Five vertical turbine type high lift pumps to Distribution
- Post-chlorine gas addition to Distribution with continuous monitoring
- Hydrofluosilicic acid (fluoride) addition to Distribution with continuous monitoring
- Filter backwash system consisting of two filter backwash pumps, serving all filters
- Backwash wastewater discharge to the backwash settling tanks
- Three backwash settling tanks; supernatant return to Sturgeon River; settled sludge to sludge thickening tanks
- Two square sludge thickening tanks; sludge discharge to municipal sewage collection system; supernatant return to the Sturgeon River
- Back-up diesel powered generator capable of servicing essential plant operations

**List all water treatment chemicals used over this reporting period**

- Polyaluminum chloride – for coagulation
- Specialty polymer – a coagulant aid
- Limestone – for raw water alkalinity adjustments to improve coagulation
- Chlorine (gas) – for primary and secondary disinfection
- Hydrated lime (calcium hydroxide) – for finished water pH adjustment
- Hydrofluosilicic acid – fluoridation
- Corrosion control and manganese sequesterant

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment
- Not Applicable

**Please provide a brief description and a breakdown of monetary expenses incurred**

Water Plant Material/Supplies/Rentals/Maintenance	\$142,208
Water Plant Process Chemicals	\$160,839
Water Quality Lab Testing	\$24,762
Consulting/Operator Training	\$16,358
Water Plant Utilities	\$218,375
Insurance	\$34,719
Labour	\$229,314
Electrical/Instrumentation	\$8,001

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Units	Corrective Action	Corrective Action Date
	Nil				

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Results CFU/100mL (min #)-(max #)	Range of Total Coliform Results CFU/100mL (min #)-(max #)
Raw	53	<10 – 60*	90 – 1460*
Treated	53	0 – 0	0 – 0
Distribution	265	0 – 0	0 – 0

\* NDOGT (No Data Overgrown with Target) reported for July 8 and July 15, 2019 samples.

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Daily Average: 0.05 - 0.98 NTU
Chlorine	8760	Daily Average: 0.91 - 1.74 mg/L
Fluoride	8760	Daily Average: 0.02 - 0.80 mg/L

**NOTE:** For continuous monitors use 8760 as the number of samples.

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Sampled	Result	Unit of Measure
March 31, 2016 – MDWL 202-102	Backwash SS	44 samples	3.6	mg/L (annual average)

**Summary of Inorganic and Organic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Fluoride	2019-08-27	< 0.1	mg/L	No
Nitrite (N)	2019-03-18	< 0.1	mg/L	No
	2019-06-10	< 0.1		No
	2019-08-27	< 0.1		No
	2019-11-20	< 0.1		No
Nitrate (N)	2019-03-18	< 0.1	mg/L	No
	2019-06-10	< 0.1		No
	2019-08-27	< 0.1		No
	2019-11-20	< 0.1		No
Haloacetic Acids (Running Annual Averages)	2019-03-18	27.3 (26.5)	µg/L	No
	2019-06-10	42.8 (31.6)		No
	2019-08-27	30.0 (31.2)		No
	2019-11-20	43.2 (35.8)		No
Antimony	2019-08-27	< 0.0001	mg/L	No
Arsenic	2019-08-27	0.0003	mg/L	No
Barium	2019-08-27	0.014	mg/L	No
Boron	2019-08-27	< 0.005	mg/L	No
Cadmium	2019-08-27	< 0.000015	mg/L	No
Chromium	2019-08-27	< 0.002	mg/L	No
Lead	2019-09-02	0.00017	mg/L	No
Mercury	2019-08-27	< 0.00002	mg/L	No
Selenium	2019-08-27	0.002	mg/L	No
Sodium	2019-08-27	1.5	mg/L	No
Uranium	2019-08-27	< 0.00005	mg/L	No
Benzene	2019-08-27	< 0.5	µg/L	No
Carbon Tetrachloride	2019-08-27	< 0.2	µg/L	No
Dichlorobenzene, 1,2-	2019-08-27	< 0.5	µg/L	No
Dichlorobenzene, 1,4-	2019-08-27	< 0.5	µg/L	No
Dichloroethane, 1,2-	2019-08-27	< 0.5	µg/L	No
Dichloroethene, 1,1-	2019-08-27	< 0.5	µg/L	No
Dichloromethane (Methylene Chloride)	2019-08-27	< 5	µg/L	No
Monochlorobenzene (Chlorobenzene)	2019-08-27	< 0.5	µg/L	No
Tetrachloroethylene	2019-08-27	< 0.5	µg/L	No
Trichloroethylene	2019-08-27	< 0.5	µg/L	No
Vinyl Chloride	2019-08-27	< 0.2	µg/L	No
Total Trihalomethanes (Running Annual Averages)	2019-03-18	36 (41.4)	µg/L	No
	2019-06-10	44 (45.4)		No
	2019-08-27	53 (42.5)		No
	2019-12-11	41 (43.5)		No
Alachlor	2019-08-27	< 0.3	µg/L	No

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Atrazine + Metabolites	2019-08-27	< 0.5	µg/L	No
Azinphos-methyl	2019-08-27	< 1	µg/L	No
Benzo(a)pyrene	2019-08-27	< 0.005	µg/L	No
Bromoxynil	2019-08-27	< 0.5	µg/L	No
Carbaryl	2019-08-27	< 3	µg/L	No
Carbofuran	2019-08-27	< 1	µg/L	No
Chlorpyrifos	2019-08-27	< 0.5	µg/L	No
Diazinon	2019-08-27	< 1	µg/L	No
Dicamba	2019-08-27	< 10	µg/L	No
Dichlorophenol, 2,4-	2019-08-27	< 0.1	µg/L	No
Dichlorophenoxy acetic acid, 2,4- (2,4-D)	2019-08-27	< 10	µg/L	No
Diclofop-methyl	2019-08-27	< 0.9	µg/L	No
Dimethoate	2019-08-27	< 1	µg/L	No
Diquat	2019-08-27	< 5	µg/L	No
Diuron	2019-08-27	< 5	µg/L	No
Glyphosate	2019-08-27	< 25	µg/L	No
Malathion	2019-08-27	< 5	µg/L	No
2 methyl-4-chlorophenoxyacetic acid (MCPA)	2019-08-27	< 10	mg/L	No
Metolachlor	2019-08-27	< 3	µg/L	No
Metribuzin	2019-08-27	< 3	µg/L	No
Paraquat	2019-08-27	< 1	µg/L	No
Pentachlorophenol	2019-08-27	< 0.1	µg/L	No
Phorate	2019-08-27	< 0.3	µg/L	No
Picloram	2019-08-27	< 20	µg/L	No
Poly-Chlorinated Biphenyls (PCB's)	2019-08-27	< 0.05	µg/L	No
Prometryne	2019-08-27	< 0.1	µg/L	No
Simazine	2019-08-27	< 0.5	µg/L	No
Terbufos	2019-08-27	< 0.3	µg/L	No
Tetrachlorophenol, 2,3,4,6-	2019-08-27	< 0.1	µg/L	No
Triallate	2019-08-27	< 10	µg/L	No
Trichlorophenol 2,4,6-	2019-08-27	< 0.1	µg/L	No
Trifluralin	2019-08-27	< 0.5	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Nil			

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)